

C O P Y

INTER-OFFICE MEMORANDUM

ATTENTION OF: Mr. Howard Wright,
Legal Department, through:
G. M. Cole
R. R. Schaefer
D. G. Snider

DATE: April 11, 1975

Howard:

Please find attached to this memo, an apparent claim against the City resulting from my letter of April 1, also attached. I do not believe that I acted in haste or without reason in the request, as the two stations more proximal to where the problem was visually apparent had already complied with the same request and with negative results. I also feel that the hazard presented from significant leakage of gasoline into a sanitary sewer line warranted immediate action.

I would be pleased if your department would respond to Mr. Viles' request. If I can answer any questions, please advise.

CHC:sw

Attachments: (3)

SIGNED 1s/CHC

Charles H. Criswell
Associate Sanitary Engineer

900 S. GRANT

CITY OF SPRINGFIELD
INTER-OFFICE MEMORANDUM

ATTENTION OF MEMO TO FILE

DATE April 4, 1975

DEPARTMENT

Mr. Viles, who is leasing the service station on the Northeast Corner of Grant & Grand, called this office today and stated that he is in the process of getting his underground storage tanks air tested. He is having Southwest Equipment Co. do the testing. Mr. Viles stated that he will send us a copy of the results, as soon as the tests are finished.

900 S. GRANT

SIGNED

Eugene Pabst
Eugene D. Pabst
Water Pollution Control Inspector

April 1, 1975

Mr. Jeff Viles
600 E. Church
Aurora, Missouri

Dear Mr. Viles:

It is our understanding that you lease the service station on the Northeast corner of Grant and Grand in Springfield. The operator of the station was contacted recently by personnel from this office concerning possible leakage from your storage tanks, and referred us to you. Due to the urgency of the situation and possible health and explosion hazard, this office is requesting that you and/or the owner take immediate steps for pressure testing of your storage tanks. Please send results of this test to my attention or feel free to call me.

If we may be of further assistance or can answer any questions, please don't hesitate to call.

Yours truly,

Charles H. Criswell
Associate Sanitary Engineer
Water Pollution Control

CHC:sw

cc: Mr. Lester Jackson, Owner
Mr. Jim Burris, Regional Engineer, Missouri Dept. of Natural Resources
Public Works File ✓

900 S. GRANT